

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH  
Mrs. Sarah Kretschmer  
Hiltistraße 6  
86916 Kaufering

Dear Mrs. Kretschmer,

based on the evaluation of the Test Reports No. 60483-A001-CS-L and No. 60483-A001-L dated 2026-01-05, the testing results of the product **Hilti Fire Finish 120+ / CFP-SP WB 120+** commissioned by **Hilti Entwicklungsgesellschaft mbH** comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))

These criteria meet the requirements for low-emitting **Paints and Coatings** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System as well as credit MRc3 of the LEEDv5 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario	Individual VOCs of Concern (after 14 days)		Formaldehyde (after 14 days)		TVOC (ISO 16000-6) (after 14 days)
	Requirement	Requirement hold	Requirement	Requirement hold	Range
School Classroom	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³
Private Office	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³

Application amount: 166 grams

VOC content	VOC Limit Value*
< 1 g/L	150 g/L

\* VOC Limit Value for "Fire Proofing Coatings" (SCAQMD 1113, 02/2016)

Cologne, 2026-01-09



Marc-Anton Dobaj, M.Sc. Crystalline Materials  
(Project manager)